



TYPICAL TRENCH CROSS SECTION



TRACK CROSSING TRENCH CROSS SECTION



LEGEND	
	Crushed stone
	Washed river sand (Protective bedding soil)
	Selected material, manually compacted (Backfill material)
	Selected material, mechanically compacted (Backfill material)
	Concrete C15 HM-20
①	Earth wire
②	MV Power Cables
③	Communication cable F.O.
④	Prefabricated tiles for mechanical protection and signaling
⑤	Warning tape 200mm (Yellow)
⑥	HDPE PIPE Ø200mm
⑦	HDPE pipe Ø40mm. One piece of pipe for the crossing, no joints.
⑧	RFID transponder

Notes:

Rev	Amendments	Date	By	Chk	Auth
0		10/23	IG	FS	FS



www.slrconsulting.com

Client
Ben Sca Wind Farm Limited

Project
Ben Sca Redesign Wind Farm

Figure Title
Indicative Cable Trench Detail

Scale
1:50 @ A3

SLR Project No.
405.064982.00001

Designed IG	Drawn IG	Checked FS	Authorised FS
----------------	-------------	---------------	------------------

Date	Date 10/23	Date 10/23	Date 03/24
------	---------------	---------------	---------------

Figure Number Figure 1.13	Rev. 0
------------------------------	-----------

